



Friendship PCS (Armstrong) - Lead in Water Test Results



FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS [Armstrong]	WS-041-001	Combo Fountain	1	In nurse suite 141		Left	WF-012024-041001-06	5/6/24	FT-FY24-012024-041001-A	<1	FT-FY24-012024-041001-B	<1
Friendship PCS [Armstrong]	WS-041-002	Combo Faucet	1	In nurse suite 141		Right	WF-012024-041002-06	5/6/24	FT-FY24-012024-041002-A	<1	FT-FY24-012024-041002-B	<1
Friendship PCS [Armstrong]	WS-041-003	Cooler	1	In hallway adjacent to room 141			WF-012024-041003-06	5/6/24	FT-FY24-012024-041003-A	<1	FT-FY24-012024-041003-B	<1
Friendship PCS [Armstrong]	WS-041-004	Cooler	1	In hallway adjacent to room 134A			WF-012024-041004-06	5/6/24	FT-FY24-012024-041004-A	<1	FT-FY24-012024-041004-B	<1
Friendship PCS [Armstrong]	WS-041-005	Food Prep Sink	1	In kitchen		Left	WF-012024-041005-05	5/6/24	FT-FY24-012024-041005-A	<1	FT-FY24-012024-041005-B	<1
Friendship PCS [Armstrong]	WS-041-006	Food Prep Sink	1	In kitchen		Right	WF-012024-041006-06	5/6/24	FT-FY24-012024-041006-A	<1	FT-FY24-012024-041006-B	<1
Friendship PCS [Armstrong]	WS-041-007	Cooler	1	In hallway adjacent to girls restroom by stair 4			WF-012024-041007-06	5/6/24	FT-FY24-012024-041007-A	<1	FT-FY24-012024-041007-B	<1
Friendship PCS [Armstrong]	WS-041-008	Combo Faucet	1	In classroom reggio 3		Left	WF-012024-041008-06	5/6/24	FT-FY24-012024-041008-A	3.1	FT-FY24-012024-041008-B	<1
Friendship PCS [Armstrong]	WS-041-009	Combo Fountain	1	In classroom reggio 3		Right	WF-012024-041009-06	5/6/24	FT-FY24-012024-041009-A	<1	FT-FY24-012024-041009-B	<1
Friendship PCS [Armstrong]	WS-041-010	Combo Fountain	1	In classroom reggio 2		Left	WF-012024-041010-06	5/6/24	FT-FY24-012024-041010-A	2.4	FT-FY24-012024-041010-B	<1
Friendship PCS [Armstrong]	WS-041-011	Combo Faucet	1	In classroom reggio 2		Right	WF-012024-041011-07	N/A	FT-FY24-012024-041011-A	Non-operational	FT-FY24-012024-041011-B	Non-operational
Friendship PCS [Armstrong]	WS-041-012	Combo Fountain	1	In classroom reggio 1		Left	WF-012024-041012-06	N/A	FT-FY24-012024-041012-A	Non-operational	FT-FY24-012024-041012-B	Non-operational
Friendship PCS [Armstrong]	WS-041-013	Combo Faucet	1	In classroom reggio 1		Right	WF-012024-041013-06	5/6/24	FT-FY24-012024-041013-A	<1	FT-FY24-012024-041013-B	<1
Friendship PCS [Armstrong]	WS-041-014	Combo Faucet	1	In art center		Left	WF-012024-041014-06	5/6/24	FT-FY24-012024-041014-A	<1	FT-FY24-012024-041014-B	<1
Friendship PCS [Armstrong]	WS-041-015	Combo Fountain	1	In art center		Right	WF-012024-041015-06	5/6/24	FT-FY24-012024-041015-A	<1	FT-FY24-012024-041015-B	<1
Friendship PCS [Armstrong]	WS-041-016	Cooler	2	In hallway across from room 225			WF-012024-041016-06	5/6/24	FT-FY24-012024-041016-A	<1	FT-FY24-012024-041016-B	<1
Friendship PCS [Armstrong]	WS-041-018	Cooler	2	In hallway across from 2nd floor elevator			WF-012024-041018-06	5/6/24	FT-FY24-012024-041018-A	<1	FT-FY24-012024-041018-B	<1
Friendship PCS [Armstrong]	WS-041-019	Cooler	2	In hallway across from room 205			WF-012024-041019-07	5/6/24	FT-FY24-012024-041019-A	<1	FT-FY24-012024-041019-B	<1
Friendship PCS [Armstrong]	WS-041-022	Combo Fountain	1	In classroom 143		Left	WF-012024-041022-06	5/6/24	FT-FY24-012024-041022-A	<1	FT-FY24-012024-041022-B	<1
Friendship PCS [Armstrong]	WS-041-023	Combo Faucet	1	In classroom 143		Right	WF-012024-041023-06	5/6/24	FT-FY24-012024-041023-A	<1	FT-FY24-012024-041023-B	<1
Friendship PCS [Armstrong]	WS-041-024	Combo Fountain	1	In classroom 144		Left	WF-012024-041024-06	N/A	FT-FY24-012024-041024-A	Non-operational	FT-FY24-012024-041024-B	Non-operational
Friendship PCS [Armstrong]	WS-041-025	Combo Faucet	1	In classroom 144		Right	WF-012024-041025-06	5/6/24	FT-FY24-012024-041025-A	1.1	FT-FY24-012024-041025-B	<1
Friendship PCS [Armstrong]	WS-041-026	Combo Fountain	1	In classroom 119		Left	WF-012024-041026-06	N/A	FT-FY24-012024-041026-A	Non-operational	FT-FY24-012024-041026-B	Non-operational
Friendship PCS [Armstrong]	WS-041-027	Combo Faucet	1	In classroom 119		Right	WF-012024-041027-06	5/6/24	FT-FY24-012024-041027-A	<1	FT-FY24-012024-041027-B	<1
Friendship PCS [Armstrong]	WS-041-030	Bottle Filler	3	In hallway across from the elevator			WF-012024-041030-04	5/6/24	FT-FY24-012024-041030-A	<1	FT-FY24-012024-041030-B	<1
Friendship PCS [Armstrong]	WS-041-031	Cooler	3	In hallway across from the elevator	Low	Left	WF-012024-041031-04	5/6/24	FT-FY24-012024-041031-A	<1	FT-FY24-012024-041031-B	<1
Friendship PCS [Armstrong]	WS-041-032	Cooler	3	In hallway across from the elevator	High	Right	WF-012024-041032-04	5/6/24	FT-FY24-012024-041032-A	<1	FT-FY24-012024-041032-B	<1
Friendship PCS [Armstrong]	WS-041-033	Bottle Filler	3	In hallway adjacent to unisex locker room			WF-012024-041033-04	5/6/24	FT-FY24-012024-041033-A	<1	FT-FY24-012024-041033-B	<1
Friendship PCS [Armstrong]	WS-041-034	Cooler	3	In hallway adjacent to unisex locker room	High	Left	WF-012024-041034-04	5/6/24	FT-FY24-012024-041034-A	<1	FT-FY24-012024-041034-B	<1
Friendship PCS [Armstrong]	WS-041-035	Cooler	3	In hallway adjacent to unisex locker room	Low	Right	WF-012024-041035-04	5/6/24	FT-FY24-012024-041035-A	<1	FT-FY24-012024-041035-B	<1
Friendship PCS [Armstrong]	WS-041-036	Bottle Filler	2	In hallway across from room 205			WF-012024-041036-03	5/6/24	FT-FY24-012024-041036-A	<1	FT-FY24-012024-041036-B	<1
Friendship PCS [Armstrong]	WS-041-037	Bottle Filler	1	In hallway adjacent to room 141			WF-012024-041037-02	5/6/24	FT-FY24-012024-041037-A	<1	FT-FY24-012024-041037-B	<1
Friendship PCS [Armstrong]	WS-041-038	Bottle Filler	1	In hallway adjacent to room 134A			WF-012024-041038-02	5/6/24	FT-FY24-012024-041038-A	<1	FT-FY24-012024-041038-B	<1
Friendship PCS [Armstrong]	WS-041-039	Bottle Filler	1	In hallway adjacent to girls restroom by stair 4			WF-012024-041039-02	5/6/24	FT-FY24-012024-041039-A	<1	FT-FY24-012024-041039-B	<1
Friendship PCS [Armstrong]	WS-041-040	Bottle Filler	2	In hallway across from 2nd floor elevator			WF-012024-041040-02	5/6/24	FT-FY24-012024-041040-A	<1	FT-FY24-012024-041040-B	<1
Friendship PCS [Armstrong]	WS-041-041	Bottle Filler	2	In hallway across from room 225			WF-012024-041041-02	5/6/24	FT-FY24-012024-041041-A	<1	FT-FY24-012024-041041-B	<1