



Friendship PCS (Ideal Campus) - Lead in Water Test Results



FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS [Ideal Campus]	WS-028-001	Break Room	1	In staff lounge across from room 157			WF-012024-028001-06	4/19/24	FT-FY24-012024-028001-A	<1	FT-FY24-012024-028001-B	<1
Friendship PCS [Ideal Campus]	WS-028-002	Cooler	1	In hallway across from room 145			WF-012024-028002-06	4/19/24	FT-FY24-012024-028002-A	<1	FT-FY24-012024-028002-B	<1
Friendship PCS [Ideal Campus]	WS-028-003	Cooler	1	In hallway across from multi purpose room			WF-012024-028003-06	4/19/24	FT-FY24-012024-028003-A	<1	FT-FY24-012024-028003-B	<1
Friendship PCS [Ideal Campus]	WS-028-006	Health Suite	1	In nursery suite			WF-012024-028006-06	4/19/24	FT-FY24-012024-028006-A	<1	FT-FY24-012024-028006-B	<1
Friendship PCS [Ideal Campus]	WS-028-007	Cooler	2	In hallway across from room 225			WF-012024-028007-06	4/19/24	FT-FY24-012024-028007-A	<1	FT-FY24-012024-028007-B	<1
Friendship PCS [Ideal Campus]	WS-028-008	Bottle Filler	1	In hallway across from multi purpose room			WF-012024-028008-02	4/19/24	FT-FY24-012024-028008-A	<1	FT-FY24-012024-028008-B	<1
Friendship PCS [Ideal Campus]	WS-028-009	Bottle Filler	1	In hallway across from room 145			WF-012024-028009-02	4/19/24	FT-FY24-012024-028009-A	<1	FT-FY24-012024-028009-B	<1
Friendship PCS [Ideal Campus]	WS-028-010	Bottle Filler	2	In hallway across from room 225			WF-012024-028010-02	4/19/24	FT-FY24-012024-028010-A	<1	FT-FY24-012024-028010-B	<1
Friendship PCS [Ideal Campus]	WS-029-016	Bottle Filler	1	In hallway adjacent to main office			WF-012024-029016-05	4/19/24	FT-FY24-012024-029016-A	<1	FT-FY24-012024-029016-B	<1
Friendship PCS [Ideal Campus]	WS-029-017	Cooler	1	In hallway adjacent to main office	High	Left	WF-012024-029017-05	4/19/24	FT-FY24-012024-029017-A	<1	FT-FY24-012024-029017-B	<1
Friendship PCS [Ideal Campus]	WS-029-018	Cooler	1	In hallway adjacent to main office	Low	Right	WF-012024-029018-05	4/19/24	FT-FY24-012024-029018-A	<1	FT-FY24-012024-029018-B	<1
Friendship PCS [Ideal Campus]	WS-029-019	Classroom Faucet	1	In Reggio suite			WF-012024-029019-05	4/19/24	FT-FY24-012024-029019-A	<1	FT-FY24-012024-029019-B	<1
Friendship PCS [Ideal Campus]	WS-029-020	Break Room	2	In room 215 teacher's lounge			WF-012024-029020-05	4/19/24	FT-FY24-012024-029020-A	<1	FT-FY24-012024-029020-B	<1
Friendship PCS [Ideal Campus]	WS-029-021	Bottle Filler	2	In hallway adjacent to girls restroom			WF-012024-029021-05	4/19/24	FT-FY24-012024-029021-A	<1	FT-FY24-012024-029021-B	<1
Friendship PCS [Ideal Campus]	WS-029-022	Cooler	2	In hallway adjacent to girls restroom			WF-012024-029022-05	4/19/24	FT-FY24-012024-029022-A	<1	FT-FY24-012024-029022-B	<1
Friendship PCS [Ideal Campus]	WS-029-023	Food Prep Sink	2	In kitchen area			WF-012024-029023-05	4/19/24	FT-FY24-012024-029023-A	<1	FT-FY24-012024-029023-B	<1
Friendship PCS [Ideal Campus]	WS-029-024	Bottle Filler	2	In cafeteria			WF-012024-029024-05	4/19/24	FT-FY24-012024-029024-A	<1	FT-FY24-012024-029024-B	<1
Friendship PCS [Ideal Campus]	WS-029-025	Cooler	2	In cafeteria			WF-012024-029025-05	4/19/24	FT-FY24-012024-029025-A	<1	FT-FY24-012024-029025-B	<1
Friendship PCS [Ideal Campus]	WS-029-026	Bottle Filler	2	In hallway adjacent to boys restrooms			WF-012024-029026-05	4/19/24	FT-FY24-012024-029026-A	<1	FT-FY24-012024-029026-B	<1
Friendship PCS [Ideal Campus]	WS-029-027	Cooler	2	In hallway adjacent to boys restroom			WF-012024-029027-05	4/19/24	FT-FY24-012024-029027-A	<1	FT-FY24-012024-029027-B	<1
Friendship PCS [Ideal Campus]	WS-029-030	Health Suite	2	In room 224 nurses suite			WF-012024-029030-05	4/19/24	FT-FY24-012024-029030-A	<1	FT-FY24-012024-029030-B	<1