



Friendship PCS (Southeast Academy) - Lead in Water Test Results



FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS [Southeast Academy]	WS-129-001	Bottle Filler	1	In hallway across from room 120	High	Left	WF-012024-129001-06	5/22/24	FT-FY24-012024-129001-A	<1	FT-FY24-012024-129001-B	<1
Friendship PCS [Southeast Academy]	WS-129-002	Cooler	1	In hallway across from room 120	Low	Right	WF-012024-129002-06	5/22/24	FT-FY24-012024-129002-A	<1	FT-FY24-012024-129002-B	<1
Friendship PCS [Southeast Academy]	WS-129-003	Cooler	1	In hallway adjacent to room 116	High	Left	WF-012024-129003-07	5/22/24	FT-FY24-012024-129003-A	<1	FT-FY24-012024-129003-B	<1
Friendship PCS [Southeast Academy]	WS-129-004	Cooler	1	In hallway adjacent to room 116	Low	Right	WF-012024-129004-07	5/22/24	FT-FY24-012024-129004-A	1.1	FT-FY24-012024-129004-B	<1
Friendship PCS [Southeast Academy]	WS-129-005	Bottle Filler	1	In hallway across from room 101	High	Left	WF-012024-129005-07	5/22/24	FT-FY24-012024-129005-A	<1	FT-FY24-012024-129005-B	<1
Friendship PCS [Southeast Academy]	WS-129-006	Cooler	1	In hallway across from room 101	Low	Right	WF-012024-129006-07	5/22/24	FT-FY24-012024-129006-A	<1	FT-FY24-012024-129006-B	<1
Friendship PCS [Southeast Academy]	WS-129-007	Bottle Filler	1	In hallway across from room 102	High	Left	WF-012024-129007-06	5/22/24	FT-FY24-012024-129007-A	<1	FT-FY24-012024-129007-B	<1
Friendship PCS [Southeast Academy]	WS-129-008	Cooler	1	In hallway across from room 102	Low	Right	WF-012024-129008-06	5/22/24	FT-FY24-012024-129008-A	<1	FT-FY24-012024-129008-B	<1
Friendship PCS [Southeast Academy]	WS-129-012	Food Prep Sink	1	In kitchen 2nd sink clockwise from door			WF-012024-129012-06	5/22/24	FT-FY24-012024-129012-A	1.8	FT-FY24-012024-129012-B	<1
Friendship PCS [Southeast Academy]	WS-129-013	Health Suite	1	In nurse office			WF-012024-129013-06	5/22/24	FT-FY24-012024-129013-A	<1	FT-FY24-012024-129013-B	<1
Friendship PCS [Southeast Academy]	WS-129-014	Bottle Filler	2	In hallway adjacent to room 203	High	Left	WF-012024-129014-07	5/22/24	FT-FY24-012024-129014-A	<1	FT-FY24-012024-129014-B	<1
Friendship PCS [Southeast Academy]	WS-129-015	Cooler	2	In hallway adjacent to room 203	Low	Right	WF-012024-129015-07	5/22/24	FT-FY24-012024-129015-A	<1	FT-FY24-012024-129015-B	<1
Friendship PCS [Southeast Academy]	WS-129-016	Classroom Faucet	1	In classroom 101			WF-012024-129016-06	5/22/24	FT-FY24-012024-129016-A	3.2	FT-FY24-012024-129016-B	<1
Friendship PCS [Southeast Academy]	WS-129-017	Classroom Faucet	1	In classroom 102			WF-012024-129017-06	N/A	FT-FY24-012024-129017-A	Non-operational	FT-FY24-012024-129017-B	Non-operational
Friendship PCS [Southeast Academy]	WS-129-018	Classroom Faucet	1	In classroom 111			WF-012024-129018-08	5/22/24	FT-FY24-012024-129018-A	1.0	FT-FY24-012024-129018-B	<1
Friendship PCS [Southeast Academy]	WS-129-020	Classroom Faucet	1	In classroom 112			WF-012024-129020-06	5/22/24	FT-FY24-012024-129020-A	<1	FT-FY24-012024-129020-B	<1
Friendship PCS [Southeast Academy]	WS-129-021	Classroom Faucet	1	In classroom 116			WF-012024-129021-08	5/22/24	FT-FY24-012024-129021-A	<1	FT-FY24-012024-129021-B	<1
Friendship PCS [Southeast Academy]	WS-129-023	Bottle Filler	1	In cafeteria			WF-012024-129023-04	5/22/24	FT-FY24-012024-129023-A	<1	FT-FY24-012024-129023-B	<1
Friendship PCS [Southeast Academy]	WS-129-024	Cooler	1	In cafeteria	High	Left	WF-012024-129024-04	5/22/24	FT-FY24-012024-129024-A	<1	FT-FY24-012024-129024-B	<1
Friendship PCS [Southeast Academy]	WS-129-025	Cooler	1	In cafeteria	Low	Right	WF-012024-129025-04	5/22/24	FT-FY24-012024-129025-A	<1	FT-FY24-012024-129025-B	<1