



Friendship PCS (Tech Prep) - Lead in Water Test Results



FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS [Tech Prep]	WS-130-001	Cooler	Ground	In hallway across gym 001 (MS)			WF-012024-130001-07	5/21/24	FT-FY24-012024-130001-A	<1	FT-FY24-012024-130001-B	<1
Friendship PCS [Tech Prep]	WS-130-002	Bottle Filler	1	In hallway adjacent to lockers by handicap ramp (MS)	High	Left	WF-012024-130002-06	5/21/24	FT-FY24-012024-130002-A	<1	FT-FY24-012024-130002-B	<1
Friendship PCS [Tech Prep]	WS-130-003	Cooler	1	In hallway adjacent to lockers by handicap ramp (MS)	Low	Right	WF-012024-130003-06	5/21/24	FT-FY24-012024-130003-A	<1	FT-FY24-012024-130003-B	<1
Friendship PCS [Tech Prep]	WS-130-004	Cooler	2	In hallway adjacent to room 201 (MS)			WF-012024-130004-06	5/21/24	FT-FY24-012024-130004-A	<1	FT-FY24-012024-130004-B	<1
Friendship PCS [Tech Prep]	WS-130-005	Bottle Filler	2	In hallway adjacent to room 201 (MS)			WF-012024-130005-03	5/21/24	FT-FY24-012024-130005-A	<1	FT-FY24-012024-130005-B	<1
Friendship PCS [Tech Prep]	WS-130-006	Bottle Filler	Ground	In hallway across gym 001 (MS)			WF-012024-130006-04	5/21/24	FT-FY24-012024-130006-A	<1	FT-FY24-012024-130006-B	<1
Friendship PCS [Tech Prep]	WS-130-009	Food Prep Sink	1	In kitchen 131A		Left	WF-012024-130009-06	5/21/24	FT-FY24-012024-130009-A	<1	FT-FY24-012024-130009-B	<1
Friendship PCS [Tech Prep]	WS-130-010	Food Prep Sink	1	In kitchen 131A		Mid	WF-012024-130010-06	5/21/24	FT-FY24-012024-130010-A	<1	FT-FY24-012024-130010-B	<1
Friendship PCS [Tech Prep]	WS-130-011	Food Prep Sink	1	In kitchen 131A		Right	WF-012024-130011-06	5/21/24	FT-FY24-012024-130011-A	<1	FT-FY24-012024-130011-B	<1
Friendship PCS [Tech Prep]	WS-130-012	Bottle Filler	1	In hallway across from room 120	High	Left	WF-012024-130012-06	5/21/24	FT-FY24-012024-130012-A	<1	FT-FY24-012024-130012-B	<1
Friendship PCS [Tech Prep]	WS-130-013	Cooler	1	In hallway across from room 120	Low	Right	WF-012024-130013-06	5/21/24	FT-FY24-012024-130013-A	<1	FT-FY24-012024-130013-B	<1
Friendship PCS [Tech Prep]	WS-130-014	Bottle Filler	1	In hallway across from room 121	High	Left	WF-012024-130014-06	5/21/24	FT-FY24-012024-130014-A	<1	FT-FY24-012024-130014-B	<1
Friendship PCS [Tech Prep]	WS-130-015	Cooler	1	In hallway across from room 121	Low	Right	WF-012024-130015-06	5/21/24	FT-FY24-012024-130015-A	<1	FT-FY24-012024-130015-B	<1
Friendship PCS [Tech Prep]	WS-130-016	Bottle Filler	1	In hallway adjacent to lab 104	High	Left	WF-012024-130016-06	5/21/24	FT-FY24-012024-130016-A	<1	FT-FY24-012024-130016-B	<1
Friendship PCS [Tech Prep]	WS-130-017	Cooler	1	In hallway adjacent to lab 104	Low	Right	WF-012024-130017-06	5/21/24	FT-FY24-012024-130017-A	<1	FT-FY24-012024-130017-B	<1
Friendship PCS [Tech Prep]	WS-130-018	Bottle Filler	2	In hallway across from room 205	High	Left	WF-012024-130018-07	5/21/24	FT-FY24-012024-130018-A	<1	FT-FY24-012024-130018-B	<1
Friendship PCS [Tech Prep]	WS-130-019	Cooler	2	In hallway across from room 205	Low	Right	WF-012024-130019-07	5/21/24	FT-FY24-012024-130019-A	<1	FT-FY24-012024-130019-B	<1
Friendship PCS [Tech Prep]	WS-130-020	Bottle Filler	2	In hallway across from room 217	High	Left	WF-012024-130020-06	5/21/24	FT-FY24-012024-130020-A	<1	FT-FY24-012024-130020-B	<1
Friendship PCS [Tech Prep]	WS-130-021	Cooler	2	In hallway across from room 217	Low	Right	WF-012024-130021-06	5/21/24	FT-FY24-012024-130021-A	<1	FT-FY24-012024-130021-B	<1
Friendship PCS [Tech Prep]	WS-130-022	Bottle Filler	3	In hallway across from room 305	High	Left	WF-012024-130022-06	5/21/24	FT-FY24-012024-130022-A	<1	FT-FY24-012024-130022-B	<1
Friendship PCS [Tech Prep]	WS-130-023	Cooler	3	In hallway across from room 305	Low	Right	WF-012024-130023-06	5/21/24	FT-FY24-012024-130023-A	<1	FT-FY24-012024-130023-B	<1
Friendship PCS [Tech Prep]	WS-130-024	Bottle Filler	3	In hallway adjacent to room 316	High	Left	WF-012024-130024-06	5/21/24	FT-FY24-012024-130024-A	<1	FT-FY24-012024-130024-B	<1
Friendship PCS [Tech Prep]	WS-130-025	Cooler	3	In hallway adjacent to room 316	Low	Right	WF-012024-130025-06	5/21/24	FT-FY24-012024-130025-A	<1	FT-FY24-012024-130025-B	<1