



Friendship PCS (Woodridge) - Lead in Water Test Results



FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS [Woodridge]	WS-068-001	Cooler	1	In hallway adjacent to JA 114	High	Left	WF-012024-068001-06	5/13/24	FT-FY24-012024-068001-A	<1	FT-FY24-012024-068001-B	<1
Friendship PCS [Woodridge]	WS-068-003	Break Room	2	In teachers lounge JA 204			WF-012024-068003-06	5/13/24	FT-FY24-012024-068003-A	<1	FT-FY24-012024-068003-B	<1
Friendship PCS [Woodridge]	WS-068-004	Cooler	2	In hallway adjacent to JA 216	High	Left	WF-012024-068004-06	5/13/24	FT-FY24-012024-068004-A	<1	FT-FY24-012024-068004-B	<1
Friendship PCS [Woodridge]	WS-068-006	Food Prep Sink	Basement	In EA basement kitchen		Left	WF-012024-068006-06	5/13/24	FT-FY24-012024-068006-A	<1	FT-FY24-012024-068006-B	<1
Friendship PCS [Woodridge]	WS-068-007	Food Prep Sink	Basement	In EA basement kitchen		Right	WF-012024-068007-06	5/13/24	FT-FY24-012024-068007-A	<1	FT-FY24-012024-068007-B	<1
Friendship PCS [Woodridge]	WS-068-008	Cooler	Basement	In cafeteria			WF-012024-068008-06	5/13/24	FT-FY24-012024-068008-A	<1	FT-FY24-012024-068008-B	<1
Friendship PCS [Woodridge]	WS-068-009	Cooler	1	In hallway adjacent to EA 113			WF-012024-068009-06	5/13/24	FT-FY24-012024-068009-A	<1	FT-FY24-012024-068009-B	<1
Friendship PCS [Woodridge]	WS-068-010	Cooler	1	In hallway adjacent to EA 102			WF-012024-068010-07	5/13/24	FT-FY24-012024-068010-A	<1	FT-FY24-012024-068010-B	<1
Friendship PCS [Woodridge]	WS-068-011	Classroom Faucet	1	In classroom EA 104		Left	WF-012024-068011-06	5/13/24	FT-FY24-012024-068011-A	<1	FT-FY24-012024-068011-B	<1
Friendship PCS [Woodridge]	WS-068-012	Classroom Faucet	1	In classroom EA 104		Right	WF-012024-068012-06	5/13/24	FT-FY24-012024-068012-A	<1	FT-FY24-012024-068012-B	<1
Friendship PCS [Woodridge]	WS-068-013	Classroom Faucet	1	In classroom EA 103		Left	WF-012024-068013-07	5/13/24	FT-FY24-012024-068013-A	<1	FT-FY24-012024-068013-B	<1
Friendship PCS [Woodridge]	WS-068-014	Classroom Faucet	1	In classroom EA 103		Right	WF-012024-068014-07	5/13/24	FT-FY24-012024-068014-A	<1	FT-FY24-012024-068014-B	<1
Friendship PCS [Woodridge]	WS-068-015	Cooler	2	In hallway adjacent to room EA 207			WF-012024-068015-06	5/13/24	FT-FY24-012024-068015-A	<1	FT-FY24-012024-068015-B	<1
Friendship PCS [Woodridge]	WS-068-017	Cooler	2	In hallway adjacent to room EA 210			WF-012024-068017-06	5/13/24	FT-FY24-012024-068017-A	<1	FT-FY24-012024-068017-B	<1
Friendship PCS [Woodridge]	WS-068-018	Break Room	2	In break room EA208			WF-012024-068018-09	5/13/24	FT-FY24-012024-068018-A	<1	FT-FY24-012024-068018-B	<1
Friendship PCS [Woodridge]	WS-068-019	Cooler	3	In hallway adjacent to room EA 307			WF-012024-068019-06	5/13/24	FT-FY24-012024-068019-A	<1	FT-FY24-012024-068019-B	<1
Friendship PCS [Woodridge]	WS-068-020	Cooler	3	In hallway adjacent to room EA 310			WF-012024-068020-06	5/13/24	FT-FY24-012024-068020-A	<1	FT-FY24-012024-068020-B	<1
Friendship PCS [Woodridge]	WS-068-021	Bottle Filler	1	In hallway adjacent to JA 114			WF-012024-068021-04	5/13/24	FT-FY24-012024-068021-A	<1	FT-FY24-012024-068021-B	<1
Friendship PCS [Woodridge]	WS-068-022	Bottle Filler	1	In hallway adjacent to EA 113			WF-012024-068022-04	5/13/24	FT-FY24-012024-068022-A	<1	FT-FY24-012024-068022-B	<1
Friendship PCS [Woodridge]	WS-068-023	Bottle Filler	1	In hallway adjacent to EA 102			WF-012024-068023-04	5/13/24	FT-FY24-012024-068023-A	<1	FT-FY24-012024-068023-B	<1
Friendship PCS [Woodridge]	WS-068-024	Bottle Filler	2	In hallway adjacent to JA 216			WF-012024-068024-04	5/13/24	FT-FY24-012024-068024-A	3.0	FT-FY24-012024-068024-B	1.1
Friendship PCS [Woodridge]	WS-068-025	Bottle Filler	2	In hallway adjacent to room EA 207			WF-012024-068025-04	5/13/24	FT-FY24-012024-068025-A	<1	FT-FY24-012024-068025-B	<1
Friendship PCS [Woodridge]	WS-068-026	Bottle Filler	2	In hallway adjacent to room EA 210			WF-012024-068026-04	5/13/24	FT-FY24-012024-068026-A	<1	FT-FY24-012024-068026-B	<1
Friendship PCS [Woodridge]	WS-068-027	Bottle Filler	3	In hallway adjacent to room EA 307			WF-012024-068027-04	5/13/24	FT-FY24-012024-068027-A	<1	FT-FY24-012024-068027-B	<1
Friendship PCS [Woodridge]	WS-068-028	Bottle Filler	3	In hallway adjacent to room EA 310			WF-012024-068028-04	5/13/24	FT-FY24-012024-068028-A	<1	FT-FY24-012024-068028-B	<1
Friendship PCS [Woodridge]	WS-068-029	Bottle Filler	Basement	In cafeteria			WF-012024-068029-04	5/13/24	FT-FY24-012024-068029-A	<1	FT-FY24-012024-068029-B	<1