



Friendship PCS (Blow-Pierce) - Lead in Water Test Results



FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS (Blow-Pierce)	WS-090-001	Cooler	1	In hallway adjacent to room 132D			WF-012024-090001-06	5/16/24	FT-FY24-012024-090001-A	<1	FT-FY24-012024-090001-B	<1
Friendship PCS (Blow-Pierce)	WS-090-003	Health Suite	1	In nurse suite 118			WF-012024-090003-06	5/16/24	FT-FY24-012024-090003-A	<1	FT-FY24-012024-090003-B	<1
Friendship PCS (Blow-Pierce)	WS-090-005	Classroom Faucet	1	In classroom 116			WF-012024-090005-06	5/16/24	FT-FY24-012024-090005-A	1.7	FT-FY24-012024-090005-B	<1
Friendship PCS (Blow-Pierce)	WS-090-006	Cooler	1	In hallway across from room 113			WF-012024-090006-09	5/16/24	FT-FY24-012024-090006-A	<1	FT-FY24-012024-090006-B	<1
Friendship PCS (Blow-Pierce)	WS-090-008	Break Room	1	In staff lounge 107B			WF-012024-090008-06	5/16/24	FT-FY24-012024-090008-A	<1	FT-FY24-012024-090008-B	<1
Friendship PCS (Blow-Pierce)	WS-090-009	Cooler	1	In hallway adjacent to room 104			WF-012024-090009-08	5/16/24	FT-FY24-012024-090009-A	<1	FT-FY24-012024-090009-B	<1
Friendship PCS (Blow-Pierce)	WS-090-010	Cooler	2	In hallway adjacent to room 218			WF-012024-090010-07	5/16/24	FT-FY24-012024-090010-A	<1	FT-FY24-012024-090010-B	<1
Friendship PCS (Blow-Pierce)	WS-090-011	Classroom Faucet	2	In classroom 218			WF-012024-090011-06	5/16/24	FT-FY24-012024-090011-A	<1	FT-FY24-012024-090011-B	<1
Friendship PCS (Blow-Pierce)	WS-090-012	Classroom Faucet	2	In classroom 217			WF-012024-090012-07	5/16/24	FT-FY24-012024-090012-A	<1	FT-FY24-012024-090012-B	<1
Friendship PCS (Blow-Pierce)	WS-090-013	Cooler	2	In hallway across from room 206			WF-012024-090013-07	5/16/24	FT-FY24-012024-090013-A	<1	FT-FY24-012024-090013-B	<1
Friendship PCS (Blow-Pierce)	WS-090-014	Classroom Faucet	3	In classroom 311			WF-012024-090014-06	5/16/24	FT-FY24-012024-090014-A	2.6	FT-FY24-012024-090014-B	<1
Friendship PCS (Blow-Pierce)	WS-090-015	Cooler	3	In hallway across from room 306			WF-012024-090015-07	5/16/24	FT-FY24-012024-090015-A	<1	FT-FY24-012024-090015-B	<1
Friendship PCS (Blow-Pierce)	WS-090-016	Classroom Faucet	3	In classroom 317			WF-012024-090016-06	5/16/24	FT-FY24-012024-090016-A	1.4	FT-FY24-012024-090016-B	<1
Friendship PCS (Blow-Pierce)	WS-090-017	Cooler	3	In hallway adjacent to room 318		Right	WF-012024-090017-07	5/16/24	FT-FY24-012024-090017-A	<1	FT-FY24-012024-090017-B	<1
Friendship PCS (Blow-Pierce)	WS-090-018	Cooler	3	In hallway adjacent to room 318		Left	WF-012024-090018-07	5/16/24	FT-FY24-012024-090018-A	<1	FT-FY24-012024-090018-B	<1
Friendship PCS (Blow-Pierce)	WS-090-019	Ice Maker	1	In kitchen			WF-012024-090019-06	N/A	FT-FY24-012024-090019-A	Non-operational	FT-FY24-012024-090019-B	Non-operational
Friendship PCS (Blow-Pierce)	WS-090-020	Bottle Filler	Ground	In gym first clockwise from entry		Left	WF-012024-090020-03	5/16/24	FT-FY24-012024-090020-A	<1	FT-FY24-012024-090020-B	<1
Friendship PCS (Blow-Pierce)	WS-090-021	Cooler	Ground	In gym first clockwise from entry		Left	WF-012024-090021-03	5/16/24	FT-FY24-012024-090021-A	<1	FT-FY24-012024-090021-B	<1
Friendship PCS (Blow-Pierce)	WS-090-022	Bottle Filler	Ground	In gym second clockwise from entry		Right	WF-012024-090022-03	5/16/24	FT-FY24-012024-090022-A	<1	FT-FY24-012024-090022-B	<1
Friendship PCS (Blow-Pierce)	WS-090-023	Cooler	Ground	In gym second clockwise from entry		Right	WF-012024-090023-03	5/16/24	FT-FY24-012024-090023-A	<1	FT-FY24-012024-090023-B	<1
Friendship PCS (Blow-Pierce)	WS-090-024	Bottle Filler	1	In hallway across from room 113			WF-012024-090024-04	5/16/24	FT-FY24-012024-090024-A	<1	FT-FY24-012024-090024-B	<1
Friendship PCS (Blow-Pierce)	WS-090-025	Bottle Filler	1	In hallway adjacent to room 104			WF-012024-090025-03	5/16/24	FT-FY24-012024-090025-A	<1	FT-FY24-012024-090025-B	<1
Friendship PCS (Blow-Pierce)	WS-090-026	Bottle Filler	2	In hallway across from room 206			WF-012024-090026-03	5/16/24	FT-FY24-012024-090026-A	<1	FT-FY24-012024-090026-B	<1
Friendship PCS (Blow-Pierce)	WS-090-027	Bottle Filler	2	In hallway adjacent to room 218			WF-012024-090027-03	5/16/24	FT-FY24-012024-090027-A	<1	FT-FY24-012024-090027-B	<1
Friendship PCS (Blow-Pierce)	WS-090-028	Bottle Filler	3	In hallway across from room 306			WF-012024-090028-03	5/16/24	FT-FY24-012024-090028-A	<1	FT-FY24-012024-090028-B	<1
Friendship PCS (Blow-Pierce)	WS-090-029	Bottle Filler	3	In hallway adjacent to room 318			WF-012024-090029-03	5/16/24	FT-FY24-012024-090029-A	<1	FT-FY24-012024-090029-B	<1
Friendship PCS (Blow-Pierce)	WS-090-030	Bottle Filler	3	In hallway adjacent to room 318			WF-012024-090030-03	5/16/24	FT-FY24-012024-090030-A	<1	FT-FY24-012024-090030-B	<1
Friendship PCS (Blow-Pierce)	WS-090-031	Bottle Filler	1	In hallway adjacent to room 132D			WF-012024-090031-01	5/16/24	FT-FY24-012024-090031-A	<1	FT-FY24-012024-090031-B	<1

FY24 Filter Test

Greater than 5 ppb - Devices Requiring Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS (Blow-Pierce)	WS-090-007	Classroom Faucet	1	In classroom 113			WF-012024-090007-07	5/16/24	FT-FY24-012024-090007-A	5.7	FT-FY24-012024-090007-B	<1

First Re-test (After Plumbing Check)

FY24 Filter Test

Greater than 5 ppb - Devices Requiring Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS (Blow-Pierce)	WS-090-007	Classroom Faucet	1	In classroom 113			WF-052024-090007-07	5/29/24	FT-FY24-052024-090007-A	7.8	FT-FY24-052024-090007-B	<1

Second Re-test (After Device Replacement)

FY24 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Friendship PCS (Blow-Pierce)	WS-090-007	Classroom Faucet	1	In classroom 113			WF-062024-090007-09	6/5/24	FT-FY24-062024-090007-A	<1	FT-FY24-062024-090007-B	<1